



California Regional Water Quality Control Board Los Angeles Region



Recipient of the 2001 *Environmental Leadership Award* from Keep California Beautiful

Linda S. Adams
Agency Secretary

320 W. 4th Street, Suite 200, Los Angeles, California 90013
Phone (213) 576-6600 FAX (213) 576-6640 - Internet Address: <http://www.waterboards.ca.gov/losangeles>

Arnold Schwarzenegger
Governor

July 1, 2008

Mr. John K. Correa
General Manager
Ojai Valley Sanitary District
1072 Tico Road
Ojai, CA 93023

Dear Mr. Correa:

**CHANGE SHEET FOR REVISED TENTATIVE WASTE DISCHARGE REQUIREMENTS (WDRs)
AND NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) PERMIT FOR
OJAI VALLEY WASTEWATER TREATMENT PLANT (NPDES NO. CA0053961, CI NO. 4245)**

Enclosed is a copy of the change sheet, which contains additional, minor revisions to the above-referenced revised Tentative Requirements, dated June 20, 2008.

As for your request to delete or modify the standard or special provisions, please understand that they are incorporated into all NPDES permits adopted by this Regional Board, as well as other Regional Boards and cannot be changed.

If you have any questions, please contact Dr. Cathy Chang at (213) 576-6664 or the undersigned at (213) 576-6720.

Sincerely,

Blythe Ponek-Bacharowski
Unit Chief, Municipal Permitting Unit (NPDES)

Enclosure

California Environmental Protection Agency



Recycled Paper

Our mission is to preserve and enhance the quality of California's water resources for the benefit of present and future generations.

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION

516TH Regular Board Meeting
Thursday, July 10, 2008 – 9:00 AM

ITEM NO. 9
ORDER NO. R4-2008-XXXX
NPDES NO. CA0053961

WASTE DISCHARGE REQUIREMENTS
FOR THE
OJAI VALLEY SANITARY DISTRICT
(OJAI VALLEY WASTEWATER TREATMENT PLANT)

CHANGE SHEET

(Deletions appear as strikethrough lines and additions appear as underlines.)

The following changes to the revised Tentative Order are clarifications suggested by Regional Board staff.

1. Tables 7a and 8 of Attachment F (Fact Sheet), pages F-32 and F-40, respectively, to be amended as follows:

Parameter	Units	Effluent Limitations					Basis
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum	
Mercury	µg/L	.054	--	0.17			SIP/CTR
	lbs/day ⁴	.0013 ²		0.0042			

2. Section V of Attachment F (Fact Sheet), page F-41 of the revised tentative permit to be amended as follows:

V. RATIONALE FOR RECEIVING WATER LIMITATIONS

B. Groundwater

Limitations in this Order must protect not only surface receiving water beneficial uses, Surface water from the Ventura River percolates into the Lower Ventura Groundwater Basin. Since groundwater from the Basin is ~~used to provide drinking water to the community~~ a potential drinking water source, the groundwater aquifer should be protected.

3. Tables 3 and 4a of **Attachment E**, pages E-8 and E-17, respectively, to be amended as follows:

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method and (Minimum Level, units), respectively
Chlorpyrifos	µg/L	24-hour composite	semiannually	⁵